



NOTES

1. All dimensions are in mm unless otherwise specified
2. All dimensions to be read off and not scaled.
3. Any discrepancies with dimensions to be notified to the Engineer before commencement of work.
4. All water pipes are HDPE and Steel pipes
5. A nominal minimum cover to reinforcement shall be 25mm
6. Marker posts shall be provided along pipelines at every 200m, except where they follow permanent roads
7. Fire hydrants are indicated FH



Client:
COAST WATER WORKS DEVELOPMENT AGENCY
 Checked, approved & signed for: **TECHNICAL SERVICES MANAGER** by:
ENG. JAMES MUTURI
 Registered Engineer's No.

Job no.:
22/01
 Job title:
SUPPLY OF WATER TO NGOMENI FISH LANDING SITE

Drawing No.:
FLS-MHG-01
 Drawing Title:
ELEVATED WATER TANKS TOWER
 Revison:
 Scale:
 Date:
 Designed by:
 Checked by:
 Drawn by:

