



REF: KE-CWSB-232660-CW-RFB (25)

DATE: 7th September, 2021

TO: All Bidders

RE: CLARIFICATION-CONSTRUCTION WORKS FOR THE SECOND BARICHO – KAKUYUNI WATER SUPPLY PROJECT – LOT 1: SECOND BARICHO – KAKUYUNI PIPELINE

CONTRACT NO: KE-CWSB-232660-CW-RFB

Clarification No. 3

The above subject matter refers.

Please find attached herewith clarifications addressing issues raised by some bidders.

Yours Sincerely,

MARTIN TSUMA
Ag. CHIEF EXECUTIVE OFFICER



CLARIFICATION NO.3 - LOT 1: SECOND BARICHO -- KAKUYUNI PIPELINE

Section	Article No.	Page No.	Inquiry	Reply/Response
Section IV-Bidding forms	Form ELI-1.1	78	Please provide the ICB No. and Title	Identification Number: KE-CWSB-232660 Title: Construction Works for the Second Baricho-Kakuyuni Pipeline Water Supply Project-Lot 1: Second Baricho-Kakuyuni Pipeline
Section IV-Bidding forms	Form EXP- (4.1-4.2abc)	92-98	Can we use our wholly-owned subsidiaries' experience?	Please refer to section III of the bidding document pages 44-47, 4. Experience 4.1(a) – 4.2(c) on compliance requirements and documentation. Take note also that the bidding document refers the Bidder or Joint Venture as appropriate
Section IV-Bidding forms	Form CCC and Form FIN-3.3	87 and 91	The qualification form does not require these documents to be completed. Please confirm if we need to fill it out.	All forms should be filled as appropriate
Section IV-Bidding forms	Form EXP- (4.1-4.2abc)	92-98	Do we need to provide proof of experience? Such as: LOA, Contract.	Proof of experience should be provided adequately.
Section II - BDS	ITB 11.1(h)	29	What documents do we need to provide regarding Schedule of suppliers?	The schedule of suppliers should include but not limited to: <ul style="list-style-type: none"> Name and Address of Manufacturer (where applicable) Country of Origin

**COAST WATER WORKS
DEVELOPMENT AGENCY
P. O. Box 90417, MOMBASA
Tel: 2315230**

				<ul style="list-style-type: none"> Name & Address of Supplier (including Country) Make/Model (Where Applicable) Applicable Quality Standard to which Material/Equipment Conforms. Manufacturer's Certificate of authorization <p>NOTE: Bidders should provide written commitment indicating that they are aware that the rates provided shall not be subject to price adjustment during contract implementation as per BDS ITB 14.5 of the bidding document.</p>
Drawings	Layout		<p>The diameter of pipe(700mm) in layout is different with BOQ (800mm). Please clarify that.</p> <p>Please provide the standard section of trench excavation for steel pipe.</p>	<p>The pipeline diameter is 800mm</p>
Drawings			<p>There is a discrepancy between words and figures regarding the amount of Bid Security in the Bidding Document. Pleas clarify</p>	<p>See additional drawing, "TYPICAL PIPE BEDDING DETAILS"</p>
ITB 19.1	<p>The amount and currency of bid security shall be Kshs. 10,000,000 (Kshs. Ten Million)</p>			<p>The amount in words prevail.</p>

