



REF: KE-CWSB-232660-CW-RFB (37)

DATE: 20th September, 2021

TO: ALL BIDDERS,

RE: CLARIFICATION-CONSTRUCTION WORKS FOR THE SECOND BARICHO – KAKUYUNI WATER SUPPLY PROJECT- LOT 1: SECOND BARICHO – KAKUYUNI PIPELINE
CONTRACT NO: KE-CWSB-232660-CW-RFB
Clarification No. 5

The above subject matter refers.

Please find attached herewith clarifications addressing issues raised by some bidders.

Yours,

MARTIN TSUMA
Ag. CHIEF EXECUTIVE OFFICER.



**CLARIFICATION NO.5: CONSTRUCTION WORKS FOR THE SECOND BARICHO – KAKUYUNI WATER SUPPLY
PROJECT-LOT 1-SECOND BARICHO KAKUYUNI PIPELINE
CONTRACT NO:KE-CWSB-232600-CW-RFB**

S/No	Article No.	Page No.	Enquiry from Bidders	Response from the client
Volume II	3.13	58	Please confirm that the price of planting the grass could not be considered during the bidding phase, if not, please clarify the species of the grass and the size of the proposed planted area.	Please refer to Volume II article 3.13 of specifications, last paragraph, all grass shall be "creeping type". Refer to Bill No.3, Item 2.1.13 the surface area is 3000m ²
Bid Guarantee			The bank has added some contents to the bid guarantee, please see the following attachments, and the added contents marked in red. Please confirm that we can use the revised bid guarantee.	As per ITB 19.1 and BDS 19.1 of the bidding document, the Bidder shall furnish as part of its bid a bid security as specified in its original form. Any additions/amendments made to the original format should not alter the meaning of Bid Security as attached in Section IV.
Section II - Bid Data Sheet	ITB 22.1	32	We kindly request to postponed the deadline of bid submission to October 15 th October, 2021	The deadline for submission of the bids remains 1 st October, 2021
Section IV-Bidding forms	Form EXP- (4.1-4.2(a)(b)(c))	92-98	According to clarification No.3, we have read the requirements and we do not see a clear explanation on whether we can use the experience of wholly owned subsidiaries. Based on our past experience, we as the parent company can use subsidiaries' experience. Please confirm.	Please refer to section III of the bidding document pages 44-47, 4. Experience 4.1(a) – 4.2(c) on compliance requirements and documentation. Take note also that the bidding document refers the Bidder or Joint Venture as appropriate. Only the experience of the Bidder or JV members (in case of JV) shall be considered and not an affiliated entity (such as parent company or group member)
Amended BoQ Volume IV	Bill No. 4 –	Item 1.9	Please note that there is still an error on the amended BOQ attached on The bill reads that the pumps should have an output of Q = 820m ³ /hr, H = 700m instead of Q = 820m ³ /hr, H = 70m	The pumps should have an output of Q = 820m ³ /hr, H = 70m